

Nitrate Treatability Study (NTS)

By:

Zach Raymond-Becker

Problem Statement



Source: Google Images – Hallmark Farmhouse

Find a solution to rural nitrate contamination in ground water for drinking in domestic households.

NTS Project

- Modeled raw ground water:
 - Ground water concentration is 20 mg/L NO₃-N and 40 mg/L SO₄
- Goal:
 - Treat modeled ground water at the flow rate of 0.2 gallons per minute to below safe levels as suggested by the Safe Drinking Water Act
 - Max Contaminant Level of 10 mg/L NO₃-N
- Success of design:
 - 80% removal of nitrate
 - Service period of 1 month
 - Low Maintenance
 - Low Cost

Presentation Outline

- Part 1 background and technology selection
- Part 2 laboratory protocol and experiments
- Part 3 scale up calculations
- Part 4 system configuration recommendations

Background

- Target group:
 - Domestic single family properties with well drinking water delivery systems in agriculturally rich areas
 - 20% of shallow aquifer wells violate the Safe Drinking Water Act's Max Contaminant Level for nitrate
- Effected population:
 - Infants
 - Elderly
 - People with weakened immune systems
- Risks due to nitrate:
 - Methaemoglobinemia or Blue Baby Syndrome
 - Shortness of breath

Technology Selection

- Nitrate removal technologies:
 - Ion exchange (adsorption)
 - Reverse osmosis (membrane filtration)
 - Electrodialysis (membrane filtration)
 - Biological denitrification
 - Chemical denitrification
- Selected Technology
 - Strong Base Ion Exchange Resin

Nitrate Selective Resin

- Purolite® A520E
- Exchange capacity:
 - 0.9 meq/mL minimum
- Functional group:
 - Quaternary Ammonium
- Resin size range:
 - 300 um to 1200 um
- Max operating temperature:
 - 212° F
- Operating pH range:
 - 4.5 to 8.5

Synthetic Water for Experiments

- Lake Mary ground water
- Spiked with:
 - Na-NO_3 and $\text{Na}_2\text{-SO}_4$
- Final Concentration:
 - 26 mg/L $\text{NO}_3\text{-N}$ and 40 mg/L SO_4



Synthetic Water Analysis

Table 1: Synthetic Water for Experiments 1 and 2							
Anions	mg/L	ppm as CaCO ₃	meq/L	Cations	mg/L	ppm as CaCO ₃	meq/L
Nitrate	114.92	93.0852	5.746	Calcium	53		2.65
Sulphate	40		0.833	Magnesium	35		2.916667
Chloride	4		0.113	Sodium	146		6.347826
Bicarbonate	320		5.245902	Potassium	0.2		0.005128
Total Anions			11.938	Total Cations			11.920
TDS=	300	mg/L		LSI=	-0.14		
T=	11.8	C		TH=	320		
P=	0.777	atm		pH=	7		

Laboratory Experiments

- Flow Through Experiment
 - 3 cycles and 33 samples per cycle
 - 10 mL A520E
 - Evaluate Recharge Ability
 - Freundlich Model
- Batch Experiment
 - Batch's 2A and 2B
 - Varied resin mass
 - Freundlich Model



Flow Through Experiment Results

- Parameters:


- $\frac{1}{n} = 1.39$

- $K_f = 8.2$

- Results:

- $q = K_f * C_{out}^{\left(\frac{1}{n}\right)}$

- $q = 21.5 \text{ ug } NO_3 - N \text{ per } mg \text{ Resin}$



$$\text{Log}(q) = \log K_f + (1/n) \log(C_{out})$$

Batch Experiment Results

- Experiment 2A
 - Source of Errors:
 - Old HACH reagents
 - Biological Activity
 - Scratched Cuvettes
- Experiment 2B
 - Samples await analysis
 - Need new reagents



Scale Up with Freundlich Parameters

- Scale up Conditions:

- $C_{in} = 20 \frac{mg}{L} NO_3 - N + 40 \frac{mg}{L} SO_4$

- $C_{out} = 2 \frac{mg}{L} NO_3 - N + 40 \frac{mg}{L} SO_4$

- $Q = 8640 \text{ gallons/month}$

- $Design \ factor = 0.85$

- Result:

- $Volume_{resin} = 3.54 \text{ ft}^3 \text{ resin}$

Scale Up using A520E Documentation

- Scale up Conditions:

- $C_{in} = 20 \frac{mg}{L} NO_3 - N + 40 \frac{mg}{L} SO_4$

- $C_{out} = 3.6 \frac{mg}{L} NO_3 - N + 40 \frac{mg}{L} SO_4$

- $Q = 8640 \text{ gallons/month}$


- $Design \text{ factor} = 0.85$

- Result:

- $Volume_{resin} = 3.50 \text{ ft}^3 \text{ resin}$


Recommended System Configuration A

- Service Pressure drop:
 - 5.79 to 13.4 PSI
- Backwash flow rate:
 - 2.2 gpm
- Regeneration volume:
 - 105 gallons
- Brine concentration:
 - 8 lb/ft³
- Temp range:
 - 41°F to 120° F



Recommended System Configuration B

- Service Pressure drop:
 - 1.37 to 3.96 PSI
- Backwash flow rate:
 - 5 gpm
- Regeneration volume:
 - 105 gallons
- Brine concentration:
 - 8 lb/ft³
- Temp range:
 - 41°F to 120° F



Operating Conditions

Operating Conditions for Recommendations Options A and B				
Operation	Rate	Solution	Time	Amount
Service	0.2 gpm	Influent Water for treatment	30 days	8640 gallons
Backwash	2.2-5 gpm	Influent Water	7-16 minutes	35 gallons
Regeneration	1.75 gpm	8lb/ft ³ NaCl	70 minutes	120 gallons
Rinse	4.5 gpm	Influent Water	16 minutes	55 gallons
Design Backwash expansion is 50% to 75% depending on temperature				
128.5 lb NaCl required per 30 day cycle				
Regeneration takes 110 minutes				


Economic Analysis

- Initial Cost:
 - \$2,499.00 ± \$200.00 for materials and installation
- Cost Ongoing:
 - \$164.00/year for sodium chloride (NaCl)
 - \$600.00/year in regeneration man hours
- Technician rate:
 - \$25.00/hr

Distribution of Hours

Table 2: Distribution of Hours				
Task	Estimated Hours	Actual Hours	Percent of Total	Cost
Preliminary Engineering	50	30	11%	\$ 1,350.00
Technology Selection	35	30	11%	\$ 1,350.00
Experimental Protocol	25	20	8%	\$ 900.00
Project Website	14	20	8%	\$ 900.00
Laboratory Experiments	50	50	19%	\$ 2,250.00
Scale up Calculations	50	40	15%	\$ 1,800.00
System Recommendation	57	25	9%	\$ 1,125.00
Final Report	35	30	11%	\$ 1,350.00
Final Presentation	10	20	8%	\$ 900.00
Totals	326	265	81%	\$ 11,925.00

Project Organization



Conclusion

- Project Objectives:
 - 80% removal of nitrate
 - Service period of 1 month
 - Low Maintenance
 - Low Cost



Questions?

