

2017

---

Abdulaziz Alanzi  
Abdullateef Alhumaidan  
Galen Geislinger  
Thomas Hill  
Brianna Moore  
Clayton Surratt

---

**FINAL REPORT**

**NORTHERN  
ARIZONA  
UNIVERSITY**



**Abdulaziz Alanzi**  
**Abdullatif Alhumaidan**  
**Galen Geislinger**  
**Thomas Hill**  
**Brianna Moore**  
**Clayton Surratt**

# **SRP FLUIDS ANALYSIS**

Midpoint Report  
**2016-17**

**Project Sponsor: Salt River Project**

**Faculty Advisor: Dr. David Trevas**

**Sponsor Mentor: Vy Kieu**

**Instructor: Dr. David Trevas**

## DISCLAIMER

This report was prepared by students as part of a university course requirement. While considerable effort has been put into the project, it is not the work of licensed engineers and has not undergone the extensive verification that is common in the profession. The information, data, conclusions, and content of this report should not be relied on or utilized without thorough, independent testing and verification. University faculty members may have been associated with this project as advisors, sponsors, or course instructors, but as such they are not responsible for the accuracy of results or conclusions.

## ACKNOWLEDGEMENTS

We thank Dr. David Trevas our faculty advisor for his time and effort, and for sharing his solutions and ideas with us as a team. We also thank Salt River Project for giving us this opportunity. We are also thankful for Vy Kieu's assistance in providing us with the appropriate data needed to successfully find a solution. We also would like to thank Dr. Tom Acker for providing us many useful resources from his books and knowledge.

## Table of Contents

<b>DISCLAIMER</b>	i
<b>ACKNOWLEDGEMENTS</b>	ii
<b>1</b>	6
1.1	6
1.2	6
1.3	6
1.3.1	6
1.3.2	7
1.3.3	7
1.3.4	7
<b>2</b>	8
2.1	8
2.2	8
2.3	9
2.4	9
2.5	10
<b>3</b>	12
3.1	12
3.2	12
3.2.1	12
3.2.2	13
3.2.3	13
3.3	13
3.3.1	14
3.3.1.1	14
3.3.1.2	15
3.3.1.3	15
3.3.2	15
3.3.2.1	15
3.3.2.2	15
3.3.2.3	16
3.3.3	16
3.3.3.1	16
3.3.3.2	16
3.3.3.3	16

<b>4</b>	17
4.1	17
4.2	17
4.3	18
4.4	18
4.5	19
4.6	20
4.7	20
4.8	21
4.9	21
4.10	22
<b>5</b>	23
5.1	23
5.2	25
5.2.1	25
5.2.2	27
<b>6</b>	28
<b>7</b>	30
7.1	30
7.1.1	30
7.2	31
7.2.1	31
7.2.2	31
7.2.3	31
7.2.4	33
7.2.5	35
7.2.6	37
7.2.7	39
7.2.8	40
<b>References</b>	29
<b>Appendix A</b>	31

# 1 BACKGROUND

## 1.1 Introduction

This project is sponsored by Salt River Project (SRP) located in Phoenix, AZ who supplies power to one million customers in the Phoenix area. SRP has 12 power plants which use a fuel measurement system that was evaluated for redesign. The goal was to improve the fuel measurement in both fuel measurement accuracy and to improve the process efficiency of SRP’s natural-gas-fired power plants. This project interests SRP because they want their plants to be at the maximum possible efficiency and fuel measurement accuracy so that they may continue serving their 1 million customers. These results would benefit Phoenix as a whole because increased efficiency at SRP’s natural gas-fired power plants would result in less waste, saving the consumer money. A more efficient natural-gas process will not only benefit SRP but is important to finding a solution to the energy crisis, especially as natural gas is an increasingly common and cheap energy source.

## 1.2 Project Description

Following is the original project description given to the SRP Fluids Analysis group from SRP.

“The project goal will be to improve fuel measurement accuracy and process efficiency at each of SRP’s natural-gas power plants. In order to succeed, the project team will collaborate with engineers, operators, and instrument technicians at several SRP power plants. Project scope includes assessment of fuel delivery systems, fuel measurement devices, fuel flow calculations, power plant operations, and multi-department process coordination.”

## 1.3 Original System




Figure 1.3: Original System Diagram

### 1.3.1 Original System Structure

SRP buys their natural gas from the company Kinder Morgan, the largest energy infrastructure company in North America. The Orifice Plate is a device used to measure flow rate and restrict

pressure or flow rate. The Rosemount and Flo Boss are both connected to the Orifice Plate and both pick up pressures and flow rates. The difference between the two is that the Flo Boss can also read temperatures.

### **1.3.2 Original System Operation**

SRP first receives their natural gas from Kinder Morgan which is then pumped into SRP's fuel measurement system. The gas passes through the orifice plate that measures the gas and sends the readings to the Rosemount transmitter and the Flo Boss which is more of a redundancy for the gas readings. The gas continues past the Orifice Plate and goes into the system where it's put through a process where the temperature is 1000 F making steam. The steam is then put through steam turbines and converted into energy.

### **1.3.3 Original System Performance**

SRP has sent the team a few files that have helped with coming up with reasonable redesign ideas and concept generations. SRP provided us with all metering information going from gas composition, differential pressure, to the temperature inside the pipe. SRP also sent the team gas prices and some receipts from Kinder Morgan compared to their metering which shows difference in measurements, which one of your members will be doing an analytical analysis on.

### **1.3.4 Original System Deficiencies**

One main reason SRP needs to redesign their fuel measurement system is because of a 2% error margin. Kinder Morgan supplies SRP with natural gas. Both companies make gas measurements on their portions of the gas transport system, with their measurements differing by 2%. The project goal was to minimize this 2% error while staying within the allotted budget.



## 2 REQUIREMENTS

The following customer requirements define the project's priorities and identify which goals may conflict with each other. They consider economic, technical, regulatory, and political aspects of the project, offering a more complete and realistic design. Each requirement is weighted to show its importance, which will be useful when making decisions about conflicting goals.

### 2.1 *Customer Requirements (CRs)*

The team has created 11 Customer Requirements for this project. The design:

1. Will uphold the standards and comply with the regulations of SRP, with a special consideration for safety. Weighting: 10
2. Must increase the accuracy of the fuel measurement system, either by updating or replacing the current system. Weighting: 10
3. Includes redundancies so that if one part of the design fails, the entire system will continue running, as plant shut downs are extremely expensive to the company. Weighting: 9
4. Be completed under a budget of \$3000, as allotted by SRP. Weighting: 10
5. Not increase greenhouse gas emissions, to avoid contributing to global warming and adhere to governmental emission regulations. Weighting: 6
6. Be easily adoptable by current operators and easy to use. Weighting: 7
7. Will monitor gas composition in real time, so that leaks or changes in composition can be known. Weighting: 8
8. Adapt to maintain maximum accuracy and efficiency as the plan powers on and off and changes power input. Weighting: 9
9. Will be adaptable to each SRP natural-gas power plant so that the design may be as useful as possible. Weighting: 8
10. Will be reliable, as even small differences in measurements may negatively affect the error margin. Weighting: 8
11. Will meet any applicable EPA regulations. Weighting: 10

### 2.2 *Engineering Requirements (ERs)*

The previously listed Customer Requirements were then considered to create more technically specific Engineering Requirements. The design will:

1. Decrease the error in gas measurement to less than 0.5%, ideally to 0.25%.
2. Cost less than the allotted budget of \$3000, though the more cost-effective, the better.
3. Withstand measuring between 1,000 and 10,000 mcf/day, which is a measurement difference factor of 10.
4. Be able to withstand up to 100 psig of pressure.
5. Include a weather-resistant computer (or one in a weatherproof box), as the design will be exposed to the elements.
6. Include a flowmeter made of a non-corrosive material.
7. Be compatible with the existing pipe structures, which have diameters of 6 in, 14 in, and 16 in.
8. Include a real-time data display, such as an LCD screen or dial, so the operators may make measurements in the field.
9. Meet SRP and EPA safety regulations.
10. Last at least 15 years, with a design goal of 20 years.

11. Include at least 1 redundancy for every function. This may include leaving some of the existing meters in place, as the company has done with the Rosemont system.
12. Reduce the pressure drop, which is currently 0.02 psi, in order to reduce turbulence.

### **2.3 Testing Procedures (TPs)**

1. The fluid dynamics for each type of meter are to be tested using computer modeling. First, the team developed MATLAB code to help with more simple math, and then a model of each meter was tested using numerical analysis techniques, showing potential losses in energy, laminar and turbulent flows, and overall which meters will perform the best.
2. The team can test various meters in Northern Arizona University's thermofluids lab. This can be done by setting up a loop with a fluid, whose properties can be easily determined or measured, air would be a common fluid to use. This loop of chosen fluid then can be directed through various meters of the team's choosing and pressure differences can be measured with pressure taps and a data acquisition device. This data will allow the team to determine the amount of pressure drop for each meter and infer which meter would be best for the application.
3. Economic analysis
4. Because the meter was purchased from a manufacturer instead of fabricated by the team, manufacturer's specs was used to evaluate whether certain engineering requirements have been met, such as life expectancy.

### **2.4 Design Links (DLs)**

1. In order to comply with the engineering requirement where the gas measurement has to be less than 0.5%, the team suggested the idea where as long as the design has a very low pressure drop, lower than the existing design, it will satisfy this requirement.
2. The team's design is considered to be a bit off the budget, where the estimated price is \$4000 and our allotted budget is \$3000. However, our allotted budget could be flexible and might be able to cover the cost.
3. According to the analytical analysis made on the Venturi flowmeter, the team obtained a turndown ratio less than ten, which satisfies this criterion in particular. Also, the Venturi flowmeter withstands measurements between 1000 and 10000 mcf/day.
4. The team planned to use AISI 1020 steel as the material for the design. The AISI 1020 steel has a tensile strength more than 5000 psi. Therefore, the material withstands pressure that exceeds 100 psig. It is also considered to be a non-corrosive material, and meets the required 15 year design life.
5. See number 4
6. The manufacturer who is supplying the Venturi meters for our team has the option to change the diameter of the flowmeter to anything necessary. So, it was easy to purchase meters of the correct diameter to be compatible with the pipe.
7. After inspecting EPA and discussing with SRP their safety regulations. The team can safely say that the final design meets SRP and EPA safety regulations.
8. See number 4
9. There are three units that need to be fitted with flowmeters. So, in order to create a redundancy the team can purchase a total of four flowmeters for the units. Purchasing the extra flowmeter will make it so that in the event of a failure the extra flowmeter can be installed instead of fixing the broken one.

- To reduce the pressure drop experienced by the existing orifice plate, the team implemented a Venturi tube meter, which due to the geometry of the venturi tube, will create less of a pressure drop. This is due to the converging and diverging sections of the pipe keeping the total head of the fluid constant throughout the meter.

### 2.5 House of Quality (HoQ)

A House of Quality (HoQ) demonstrates Customer and Engineering Requirements and how they relate and possibly conflict with each other. It is helpful in understanding goal parameters. At this stage, the HoQ (Appendix) lists the Customer Requirements and their weights out of 10, the Engineering Requirements, and Targets and Tolerances for the Engineering Requirements, which show the design goals.

House of Quality (HoQ)												
Customer Requirement	Weight	Engineering Requirement	Decrease error to 0.5% or less	Cost < \$3000	Able to measure between 1000 & 10000 mcf/day	Able to withstand 100 psig	Non-corrosive material (or corrosive-resistant) for flowmeter	Flowmeter compatible with pipe of 6, 14 or 16 in diameter	Meet SRP/EPA safety regulations	Able to last 10 years	At least 1 redundancy for every function	Pressure drop <0.002psig
1. Meet company and safety regulations	10		0	0	0	9	9	1	9	3	9	0
2. Increase fuel measurement accuracy	10		9	1	9	0	1	1	1	1	9	1
3. Include redundancies	9		1	3	3	3	3	1	9	9	9	0
4. Expenses < \$3000	10		3	9	3	3	9	3	3	9	9	9
5. Adapt to on/off/ramping cycling	9		9	3	9	3	0	0	0	3	1	3
6. Implementable on multiple sites	8		1	1	3	3	3	9	9	3	1	1
7. Reliable	8		3	0	9	9	9	1	1	9	9	3
8. Meet EPA regulations	10		0	3	0	3	9	0	9	1	0	0
<b>Absolute Technical Importance (ATI)</b>			242	192	324	300	403	139	381	344	440	159
<b>Relative Technical Importance (RTI)</b>			7	8	5	6	2	10	3	4	1	9
<b>Target(s), with Tolerance(s)</b>			0.25% (<0.5%)	\$2000 (<\$3000)	Factor of 14 (>10) difference	130 (>100) psig	N/A	6 in, 14 in, 16 in	N/A	20 (>10) years	N/A	0.01 (<0.02) psig
<b>Testing Procedure (TP#)</b>			1,2	3	4	4	4	1,2,4	4	4	1,2	1,2
<b>Design Link (DL#)</b>			1	2	3	4	4	5	7	4	9	10

Figure 2.5: House of quality



### 3 EXISTING DESIGNS

The following information regards existing designs that are currently in use for the entire process of converting natural gas into useable energy. This section will elaborate on current industry practices and the team's rationale as to why these industry practices are relevant to our design process.

#### 3.1 *Design Research*

In order to get an accurate idea of what the usual practices and industry standards are for natural gas plants the group conducted extensive research into contemporary natural gas systems and subsystems. For system level design the areas that were focused on were the measurement of the natural gas and the general thermodynamic processes that take place for converting natural gas into useable energy. For subsystems the areas that were researched were specific measurement techniques, transportation methods, and turbine designs used in natural gas plants.

The main source of information gathered during our design research was published research and informative articles found via the internet. Specific calculations were difficult to find via open source online information due to the fact that this sort of information is proprietary to each respective natural gas company. However, online research was extremely valuable for obtaining system overviews and rationale as to why certain design decisions are made by natural gas distributors and energy generation companies. Specific information regarding the specifications of our design will be supplied by our client contact at SRP and will be included in subsequent reports.

#### 3.2 *System Level*

One of the preliminary steps in designing or improving a system is to find out what the standard practices are for similar systems. With this in mind two areas were focused on in the research of existing systems, they were methods of natural gas measurement and methods of converting natural gas into useable energy.

Included in existing designs is an example of a state of the art natural-gas measurement system being used in Turkey and two examples of the two most common methods of natural-gas combustion. These three existing designs were selected because both measurement and energy generation techniques are extremely pertinent to our design process going forward.

##### 3.2.1 **Existing Design #1: Turnkey Gas Measurement System**

One of the existing systems that was researched was the Turnkey Gas Measurement System designed by Botas, which is the state owned oil and gas company in Turkey. The system was designed to compress natural gas to 75 bar at flow rates that vary between 510,000 and 2,040,000 Sm<sup>3</sup> per hour [1]. This pressure and flow rate need to be maintained during all seasons, which can be a challenge in a country with a volatile climate, like Turkey.

A few of the elements of the Botas systems that differ from similar systems designed by different companies are that the Botas system has all components designed together as a package, instead of separate, and the Botas system has numerous intended redundancies incorporated into it [1]. The benefits of having all of the components designed as one package are that cost is significantly reduced, and the chance of components not integrating with each other successfully is significantly mitigated. The purpose of the redundancies in the system is to attempt to eliminate the risk of one component malfunction causing the system to shut down. In the energy industry downtime can be extremely expensive, so it was determined that it would

be more cost effective to allocate more resources to creating redundancies in the design and reduce the chance of the entire system needing to be shut down for maintenance.

### **3.2.2 Existing Design #2: Simple Cycle Power Plant**

One of the existing types of natural gas energy generation systems is the simple cycle natural gas power plant. This system works by performing a basic cycle where natural gas is combusted which causes the gas to expand and rotate a series of blades attached to the shaft. This causes the shaft to turn and spin a generator which produces electricity. One of the issues with simple gas turbines is that the process efficiency is only 20-35% [2]. The benefit of a simple cycle over the other types of cycles is that a simple cycle is much less expensive to initially design and build. This makes it so that for areas where a small amount of energy is need a simple power cycle will make more sense. For areas where a large amount of energy is needed it makes more sense to invest in a more efficient system

### **3.2.3 Existing Design #3: Combined-Cycle Power Plant**

One of the existing systems researched is the combined-cycle power plant. This plant uses gas and steam turbines that produce up to 50 percent more electricity, using the same amount of fuel than the traditional simple-cycle plant [3]. Any heat waste from the system is also rerouted to the steam turbine, and generates more power.

This system works by first the gas turbines burn the fuel put into the system. The gas turbine compresses the air and mixes it with fuel at a high temperature. The heated air moves through the turbine blades making them spin. The fast spinning blades drives the generator that converts some of the energy into useful electrical power. The combined-cycle plant also has a heat recovery system that captures exhaust [3]. A heat recovery system generator (HRSG) captures exhaust heat from the gas turbine, that would've have escaped and been wasted. Then the HRSG takes the heat and sends it to the steam turbine. The steam turbine then takes the excess exhaust waste and makes it into useful electrical power.

## **3.3 *Subsystem Level***

Throughout our research of existing system level designs it became apparent that there are three subsystem levels that are the most important to the process of converting natural gas into useable energy. The functional model (Figure 3.1) in the figure below describes the measured flow at SRP's Agua Fria plant. Kinder Morgan sends its fluid to SRP's pipeline to be measured through an orifice plate that is being calculated by a flow computer, the FloBoss. The rest of system is how energy is transformed from mechanical energy to electricity. These subsystems are: measurement of incoming natural gas, transportation of that natural gas, and the different kinds of turbines used to convert combusted gas into energy. In the following sections the importance of these three subsystems and the specific methods used in these subsystems is explained in detail.




Figure 3.1: Functional model of the natural gas system at the Agua Fria plant

### 3.3.1 Subsystem #1: Measurement

The general idea of measurement on this subsystem is coming from adsorption operation. There are commonly used sorbents like zeolites or activated carbons. The method and designs to calculate the mass of a gas are various, but the three existing designs that will be discussed here are the Volumetric, Gravimetric, and the Oscillometric chromatographic methods.

#### 3.3.1.1 Existing Design #1: Volumetric – chromatographic

The system shown is a slow processed system, because of the fact that the mixture will go through many steps to be adsorbed, but it still can give accurate measurements not just for natural gas, but also for other gasses. The way it works is by supplying a gas mixture to the storage vessel that has a certain volume and measurement for pressure and temperature [4]. The mixture from there will expand to the adsorption chamber, where it has an adsorbent that will absorb gas. The chamber also has a certain volume and measurement for pressure and temperature, which will allow a specific amount of mass for the rest of the mixture, enabling the amount of absorbed gas to be calculated. The rest of the mixture however will circulate back to the vessel storage by a circulation pump to do the process over and over again. The gas sample will provide the mass concentration, which will eventually derive an equation for the absorbed gas [4].

### **3.3.1.2 Existing Design #2: Gravimetric – chromatographic**

For the gravimetric method a microbalance is placed inside the adsorption chamber instead of two storages as the previous existing design. What this microbalance does is it will deal with weighing the mixture before and after the adsorption operation to have accurate value for the mixture and the gas. The molar mass will be needed as well and it will be calculated as before by taking a gas sample. The process can also be repeated over and over again by a circulation pump [4].

### **3.3.1.3 Existing Design #3: Oscillometric-Chromatographic**

The Oscillometric chromatographic design can calculate the mass by the frequency of oscillations of the sorbent. The number of frequency measured throughout the rotational pendulum can give specific measurement of mass from the Reynold's number equation. A formula can be derived through experiments to calculate the mass adsorbed accurately [4].

## **3.3.2 Subsystem #2: Transportation**

The transportation process of the natural gas is the most important aspect of the gas business, where usually the gas plants are not located near the main markets. In general, natural gas can be transported by pipelines, which is the method that the team will be working with during this project. The transportation of natural gas through pipelines is considered to be very complicated [5]. The pipeline network is very complex and needs to be designed to satisfy the supplier's route desire.

One way to ensure a less turbulent flow of the natural gas through pipelines is to pressurize the gas that is being transported through the pipe. Pressurizing the gas will guarantee to deliver the gas within the range of the desired rates and volumes. In addition, to ensure that the gas always pressurized throughout its transportation, compressor stations are required to compress the natural gas periodically, and this is done by placing compressor stations every 40 to 100 miles [5]. The team is required to measure the natural gas at a constant rate. So, ensuring a constant flow through the pipe will increase the accuracy of the measurements that will be done. Three types of compression engines will be discussed more in depth below.

### **3.3.2.1 Existing Design #1: Centrifugal Compressor**

The Centrifugal Compressor is a mechanical device mainly used for transporting purposes. The Centrifugal Compressor moves the natural gas within the pipeline, which in a way increases the flow speed of the gas because of the impellers that are included. In addition, the rotating blades will increase the pressure of the natural gas that is transported. They are known to change the direction of the gas flow by accelerating the gas flow within.

### **3.3.2.2 Existing Design #2: Reciprocating Engine**

Also called a piston engine, this type of engine aims to generate rotational energy from pressure. The reciprocating engine includes reciprocating pistons that play an essential role in converting the pressure into rotational energy and moves the gas inside the pipe [6]. The reciprocating engine uses the natural gas that is flowing inside the pipe to operate constantly. This engine actually works by expanding the gas at a higher temperature and uses that work to operate the pistons.



### **3.3.2.3 Existing Design #3: Hot Air Engine**

The Hot air engine is a form of compressing gas within the pipeline to help accelerate and move the natural gas to the desired location [7]. The Hot air engine takes advantage of the expansion and contraction of the gas inside the pipe, which are caused by the thermal differentiations, to convert thermal energy to mechanical energy. Based on that, it compresses the gas and pumps it through the pipeline.

### **3.3.3 Subsystem #3: Flow measurement**

During the process of natural gas transportation an accurate measurement of the flow rate is needed in order to supply the correct amount of fuel into the combustion chamber that powers the power plant. In order to get this measurement a multitude of flow measurement techniques are used. A common technique so to to create a pressure drop in the flow and measure properties across the pressure drop. Outside of this technique many others are used that do not have as much impact on the flow of the fluid. In this section these techniques will be discussed in more detail.

#### **3.3.3.1 Existing Design #1: Sonic Flowmeter**

A unique technique for measuring flow is with the use of a sonic flowmeter. The way this works is that a device is attached to the flow area that sends a pulse perpendicular through the flow. Once this pulse travels through the flow it is reflected back the way it came through the flow. Once this has made the trip through the flow again the pulse is absorbed by a transceiver. The transceiver records the time it took for the pulse to travel through the flow and from that time the flow rate can be calculated.

#### **3.3.3.2 Existing Design #2: Venturi Tube**

A Venturi tube is a flow meter that has a contraction in the pipe making the diameter smaller then getting larger again gradually to make the transition smooth and create less turbulence than an orifice plate. This contraction makes a pressure difference much like the orifice plate where the differential pressure is a key element in finding flow rate. To calculate this pressure difference a manometer is attached to different sections on the Venturi tube, preferably before and at the contraction.

#### **3.3.3.3 Existing Design #3: Coriolis Meter**

Over the past five years the Coriolis meter has been one of the fastest growing meter in the market. Just like most meters Coriolis can calculate the mass flow rate of the fluid flowing through it. Most Coriolis meters have two tubes which are made to vibrate in opposite directions of each other due to the magnetic coil. Sensors in the form of magnet and coil assemblies are mounted on the inlet and the outlet of both flow tubes. As the coils move through the magnetic field created by the magnet, they create a voltage in the form of a sine wave. These sine waves are then used to calculate the mass flow rate.

## 4 DESIGNS CONSIDERED

The following designs were the 10 most plausible designs resulting from the team's brainstorming. They include types of flowmeters, changes to the existing computer system and orifice plate setup.

### 4.1 *Coriolis Mass Flowmeter*

The Coriolis flow meter is considered to be a solid design, as it offers more advanced technology in comparison with the existing design that Salt River Project unit has. The coriolis mass flow meter measures the mass flow rate of the fluid that is flowing through. The operating principle of this flowmeter is that it has two measuring tubes connected, and these two tubes deform when a fluid is flowing through. The deformation of both tubes is proportional to the mass flow rate of the fluid itself. It also has two sensors attached, one at each tube, these sensors records the motion of the tubes and translates this motion to a phase shifter diagram. The mass flow rate of the fluid is derived by taking the difference between the two phases of the tubes. In addition, the density of the fluid can be computed by determining the frequency of the phase.




Figure 4.1: Coriolis Flowmeter [8]

### 4.2 *Venturi Flowmeter*

The Venturi flowmeter measures the flow rate of the fluid that is flowing through a pipe or a tube. The theory behind the operating principle of the Venturi flowmeter is Bernoulli's law. The Venturi flowmeter measures the flow rate by decreasing the diameter of the tube along the flow path, which causes a pressure differential. The pressure differential that is created

helps compute the flow rate.

Figure 4.2: Venturi Flowmeter [9]



### 4.3 Heat Shield

This design involved applying an insulation layer to the pipes in the SRP units. By providing insulation to the pipes, the energy consumption would be reduced by 30 percent. In addition, by limiting the gain and loss of the heat in the pipe and by reducing the energy consumed, the flow meter readings will be more stabilized, and the chance of getting more precise readings will increase. This can be explained by using the relationship between density of a fluid and temperature. When the pipe is exposed to a higher temperature, the fluid will become less dense, most likely giving false readings for density and Reynolds number.

### 4.4 Turbine meter

A turbine meter uses rotation of a rotor to determine the flowrate in the pipe. This rotation is achieved by having the fluid, natural gas in this case, contact the blades of the rotor as it flows through and the force of the blades cause the rotation. This rotation is inferred into a rotational speed, usually in rpm, by a magnetic pickup. By knowing the gas composition, which is known information, the team can calculate the density of the fluid. With both the density and the rpms of the rotor the flow rate then can be calculated by a flow computer.




Figure 4.4 Turbine Flow Meter [10]

#### **4.5 *New diameter orifice plate***

A new diameter for the orifice plate can be used in order to reduce the error found in SRP's system. The original diameter can be increased so that the diameter of the orifice plate is closer to the diameter of the pipe than before. This increase in the diameter or the decrease in the difference in diameters will lead to a lower pressure drop and thus overall a lower error. This will lead to less energy loss due to turbulence in the pipe due to the orifice plate's diameter size.

#### 4.6 *Balloon meter*

The balloon meter is a simple system that utilizes a balloon as a storage device and a stopwatch as a timer. A person would fill a balloon with the natural gas in question to a known volume. This is admittedly hard to achieve accuracy with due to human error involved in the process. A stopwatch will be used to time the flow. Knowing the time and volume will then allow this person to calculate the flow rate into the balloon.




Figure 4.6: Balloon Design

#### 4.7 *Update Flo Boss*

The FloBoss system that SRP has installed now is from the 1990's about 20 years old. Since then there has been many new flow computers invented with higher accuracy and more readings than the one installed. One viable option for updating the computer would be the FloBoss 107E which is a newer and updated version of the 503 which is installed at the SRP power plant. The 107E has new gas control options that the 503 doesn't have. One new control is the option to see the potential energy in MMBtu that the gas contains. The display is updated as well and has color in the display to easily reference what is going on in the system. There is another viable option for the update and that's the 103 Flo Boss. The 103 is a much cheaper version of the 107E and has some downfalls for the reduced price. The 103 still has a high accuracy and still does some chart analysis, but doesn't have nearly as much analysis as the 107E offers.



Figure 4.7: FloBoss 107E Flow Manager [11]

### 4.8 Liquefying Gas Design

Natural gas flows to a chamber that has one inlet and one exit. The exit valve will be closed, as the gas flow will keep compressing the gas inside the chamber. The gas in the chamber will reach a certain pressure, which will make the inlet valve close. Once both valves are closed, the natural gas inside the chamber will be cooled by a condenser, which will allow the natural gas to reach its condensing point ( $T = -258.7\text{ F}$ ) or more if it needed too. The fluid will change its phase to liquid and thus will be easily scaled by a scaler inside the chamber. Once a constant amount of fluid has been calculated, the exit valve will open to send the fluid away and repeat the whole process over again when necessary.




Figure 4.8: Liquefying Design

### 4.9 Bio-Inspired Design: Flexible Venturi

One way nature regulates fluid pressure is the constriction of blood vessels in the body. This change in diameter changes the pressure of the blood flowing through the circulatory system so that it can reach all parts of the body. Thus, the flexible Venturi design comprises a portion of flexible tubing, made of silicon or a similar material, so that the diameters of the flowmeter may be changed as needed at 1 inch segments to create an ideal pressure drop and minimize turbulence after the diameter constriction.

Figure 4.9: Bio-inspired Flexible Venturi

#### 4.10 *Bio-Inspired Design: Offset Ultrasonic Flowmeter*

This design is inspired by the offset ears of owls. Their offset design allows them to better locate sources of sounds in the dark, especially in the horizontal direction. This principle may be used to modify an already existing Ultrasonic Flowmeter to make it more accurate.




Figure 4.10: Bio-Inspired Ultrasonic Flowmeter

## 5 Designs Selected

In the following section the design(s) that the team has decided to pursue will be discussed. This section will also discuss the rationale for why the selected design(s) were chosen over the other design options. There were three designs selected for presentation to the client. Three designs were selected instead of choosing one in order to leave our options open based on the feedback we receive from the client. The three designs selected were: improvement of original system (new FloBoss/ changing diameter of orifice plate), Coriolis meter, and sonic flowmeter.

### 5.1 Design Description

A Venturi flow meter is considered as one of the obstruction methods that consists of two smooth convergent entrance and divergent outlet. Figure 5.1 shows how generally a Venturi flow meter works. The venturi flow meter is being used in the industry, due to its reasonable price and its way of measuring the pressure again right at the throat to calculate the flow rate of the fluid.




Figure 5.1.1: Venturi flow meter system

The standard angles of Venturi convergent entrance and divergent outlet are  
 $\theta_{\text{entrance}}=21^\circ$

$\theta_{\text{outlet}}=7^\circ$  or  $15^\circ$

The energy loss in both  $7^\circ$  and  $15^\circ$   
 are given by experiments  
 $15^\circ$  gives:

$$\begin{aligned} (\delta P)_{\text{loss}}/\delta P &= 0.436-0.86\beta \\ &+0.59\beta^2, \text{ where } \beta \\ &= d/D \end{aligned}$$



7° gives:

$$\begin{aligned} &(\delta P)_{\text{loss}}/\delta P \\ &= 0.218 - 0.42\beta \\ &+ 0.38\beta^2 \\ &\text{where } \beta = d/D \end{aligned}$$

These two equations can be applied on a wide range of Reynold's numbers, but it can get too accurate with high Reynold's numbers that ranges between  $2 \cdot 10^5 < Re < 2 \cdot 10^6$  and  $0.4 < B < 0.75$ , because experimentally, those values will make the Venturi flow meter able to almost neglect the discharge coefficient "C". Also the energy loss with this range of Reynold's numbers will give exactly 10% energy loss with the same range of B. The main equation used to calculate the flow rate of a compressible flow is

$$Q = (K \cdot A_2 \cdot Y / \rho) / (2 \cdot g \cdot \rho \cdot \Delta P)^{0.5}$$

The assumption made for the design selected has the exact same dimensions for the orifice plates except that the expansion factor Y will be different in a Venturi than an orifice plate, the calculation made in the appendix is based on many assumptions that can be accomplished when designing the flow meter. The calculation might be close between the Venturi and orifice, because it is also assumed that the pressure reading of the venturi is the same as the orifice, however, in testing the procedure the Venturi should have better readings than the orifice plate based on the research comparison made between them.




Figure 5.1.2: Venturi design isometric view




Figure 5.1.3: Venturi design right view

The Venturi design shown in the figures is a sample of is expected to be replaced with the orifice meters. The type of metal used has to match the pipes metal, also the geometry of the inlets and outlets will be based on the unit number in SRP.

## 5.2 *Rationale for Designs Selected*

At the beginning of the design process the team compiled a list of ten possible designs. In order to narrow down this list the team imported these ten designs into a Pugh Chart, and a decision matrix. These two methods allow for a more analytical approach to be taken towards design selection. In the following sections these methods will be explained in more detail.

### 5.2.1 Pugh Chart

A pugh chart is an analytical tool that is used to compare considered designs with a baseline design, this baseline design is called the datum. The way the Pugh Chart works is that a variety of important categories are selected and each design is judged as either better (+) or worse (-) than the datum in each category. All of the +'s and -'s are then added up and the designs with the higher scores are judged to be better by the Pugh Chart.

The selected datum for our Pugh Chart was chosen to be the changing orifice diameter design. This was selected because besides changing the orifice diameter the rest of the system will stay the same with this design. This will allow us to compare the individual components of each considered design with the current design. Our categories in the Pugh Chart were taken fairly directly from the engineering requirements, meaning that the categories on the Pugh Chart correspond one-to-one to the categories on the HOQ.

After completing the scoring process there were six designs that stood above the rest on the Pugh Chart scoring. The highest scoring designs were: new FloBoss, changed orifice plate diameter, Venturi meter, Coriolis meter, turbine meter, and sonic flowmeter

	New Flo-Boss	Venturi meter	Bio-inspired Diameter Restriction	Liquefy gas	Sonic Flowmeter	Coreolius	Turbine	New diameter orifice plate	Heat shield	Balloon inflation
Decrease error	+	+	+	+	+	+	+	D	-	-
Low Cost	-	-	-	-	-	-	-		-	+
Range of volume measurement	S	+	+	+	S	S	+	A	-	-
Low pressure drop	S	+	+	-	+	+	+		S	-
Durability of flowmeter	S	+	-	-	-	-	-	T	+	-
Weatherproof computer or in weatherproof box	+	S	S	S	S	S	S		S	+
Non-corrosive/corrosive-resistant material for flowmeter	S	+	-	-	+	-	-	U	+	S
Flowmeter compatible with existing system	S	-	-	-	-	-	-		-	-
Real time display of data (LCD or dial)	+	S	S	S	S	+	S	M	S	-
Meet SRP/EPA regulations	S	S	S	-	S	S	S		S	-
1 redundancy for every function	+	S	-	-	-	S	S		S	-
Totals	+3	+3	-2	-5	0	0	0	0	-3	-6

Figure 5.2.1: Pugh Chart

### 5.2.2 Decision Matrix

After completing the Pugh Chart there were six designs that scored significantly higher than the rest, these six designs were then put into a decision matrix. The decision matrix has the same categories as the Pugh Chart, but in the decision matrix these categories were each given a weight based on their importance to the success of the design.

The category that was given the highest weight was the ability of the design to decrease the error in the measurement system. This was given the highest weight because it is imperative that the design decreases the system error as this is the main project goal. Another important category was having a low pressure drop across the measurement apparatus. Having a large pressure drop leads to a larger amount of turbulence which can lead to more error in the system, in addition a large pressure drop causes greater energy loss, which is an outcome that should be mitigated as best as possible. Compatibility with the existing system and meeting EPA/SRP regulations were also major design considerations.

Weighting		New Flo-Boss	Venturi meter	Sonic Flowmeter	Coreolius	Turbine	New diameter orifice plate
Categories							
Decrease error	0.30	60 (18)	65 (19.5)	55 (16.5)	90 (27)	80 (24)	60 (18)
Low Cost	0.05	90 (4.5)	30 (1.5)	80 (4)	30 (1.5)	50 (2.5)	100 (5)
Range of volume measurement	0.10	90 (9)	90 (9)	60 (6)	90 (9)	60 (6)	90 (9)
Low pressure drop	0.20	50 (10)	60 (12)	100 (20)	80 (16)	70 (14)	55 (11)
Durability of flowmeter	0.03	60 (1.8)	90 (2.7)	70 (2.1)	70 (2.1)	65 (1.95)	90 (2.7)
Weatherproof computer or in weatherproof box	0.02	90 (1.8)	80 (1.6)	80 (1.6)	80 (1.6)	80 (1.6)	80 (1.6)
Non-corrosive/corrosive-resistant material for flowmeter	0.02	80 (1.6)	80 (1.6)	60 (1.2)	80 (1.6)	80 (1.6)	80 (1.6)
Flowmeter compatible with existing system	0.10	100 (10)	40 (4)	80 (8)	60 (6)	40 (4)	100 (10)
Real time display of data (LCD or dial)	0.04	100 (4)	80 (3.2)	80 (3.2)	80 (3.2)	80 (3.2)	80 (3.2)
Meet SRP/EPA regulations	0.10	90 (9)	90 (9)	90 (9)	90 (9)	90 (9)	90 (9)
1 redundancy for every function	0.04	90 (3.6)	70 (2.8)	90 (3.6)	70 (2.8)	70 (2.8)	80 (3.2)
Total	1.00	73.3	66.9	75.2	79.8	70.65	74.3

Figure 5.2.2: Decision Matrix

## 6 Proposed Design

The implementation of our design will be fairly simple. We simply need to purchase 3 units of our selected flowmeter and then install these three units in the existing fuel measurement areas in the SRP power plants. So, the only two major costs in the implementation process will be the cost of purchasing and the cost of installing the system. Pricing for the units was found using the prices given by AFT instrument for their LGW classic venturi tube. This listing was found on Alibaba.com [13], a link to the specific listing can be found in the references section. Cost of installation were assumed using information found online. The total pricing for the installation is listed in the table below. The total budget for our team was listed as \$3000 so the installation cost will fall within our budget with a margin for error to account for any unforeseen costs.

Table 6: Installation Costs

	Purchasing cost	Installation cost	Total cost
Per unit	\$500	\$300	\$800
Total (3 units)	\$1500	\$900	\$2400

## 7 Implementation

This section will include a brief description of the manufacturing process, as well as the bill of materials. The bill of materials will describe each item that will be used in the experiment, along with the items price and manufacturer.

### 7.1 Manufacturing

For the design of our experiment there was little manufacturing that needed to be done in terms of machining parts. Instead, all of our individual components were purchased premade from retailers and the experiment will be assembled by hand by the group members using basic tools such as hack saws and adhesive tape. A detailed list of all components for our experiment is listed below in the bill of materials.

#### 7.1.1 Bill of Materials

Table 7.1.1: Bill of Materials

Material	Source	Cost
Venturi Tube with pressure tap	Pasco	\$150.00
Pasco Airlink	Pasco	\$59.00
6 pressure taps	Pasco	\$100.00
3-D printed nozzle	NAU cline library	\$30.00
Adhesive Tape	Home Depot	\$8.00
20 feet of ¾ in PVC piping	Home Depot	\$7.00
3 straight ¾ in PVC couplers	Home Depot	\$2.50
3 90 degree bend PVC couplers	Home Depot	\$2.50
Washers of various diameter	Home Depot	\$4.50
<b>Total</b>		<b>\$363.50</b>

As shown in the above table there were two main retailers that the components for the experiment were purchased from. These retailers were Pasco and Home Depot. Pasco is a company that mainly specializes in technology used by high school and college educators to run science experiments. So, they had a plethora of flow sensors and equipment used for flow measurement at very reasonable prices. For these reasons they were a very good choice to

purchase our electronic flow measurement equipment from. The other major retailer we used was Home Depot. The equipment we purchased from them was the basic components we are going to use to construct our piping system. The reason they were chosen to purchase our equipment from is that there is a Home Depot store in close proximity to campus, and the equipment there is priced extremely inexpensive.

As listed above after all purchasing was completed the total cost come out to \$363.50. The budget for this project given to us by Northern Arizona University is \$3,000. The group does not foresee any more major expenses, so we anticipate that by the end of the project we will be well within our budget range.

## **7.2 Design of Experiment**

For the final deliverable the team is constructing a lab experiment that simulates SRP's fuel measurement system. The lab will be conducted in the thermal fluids lab at Northern Arizona University (NAU).

### **7.2.1 Experimental Overview**

This lab will test the team's theory that a Venturi is more accurate than a orifice. This lab will consist of building an experimental apparatus that fully represents the pipe structure of SRP. For the piping the team will use various lengths of PVC to test different entry lengths to the flow meter. The flow meters that will be used in the lab consist of a Venturi tube and a few different size orifices that all will be tested to see the most accurate flowmeter. For this experiment the team will be using air from the blower in the thermal fluids lab. To find out the speed needed to simulate SRP's fuel system the Reynolds number was scaled from natural gas to air. This includes changing the viscosity, density, and the diameter, then using the Reynolds number for SRP's flow a velocity for air can be calculated. The velocity was found to be about 23 m/s which is definitely possible to do with the blower. The team is also setting up a DATUM, an ultrasonic flowmeter to compare with the orifice and Venturi data. The team will be using a 3D printed nozzle to converge the 4 inch blower to  $\frac{3}{4}$  inch that is needed for this experiment.

### **7.2.2 Variables**

There are a few variables that are being tested in the lab. One being different orifice diameters to calculate the more accurate sized orifice. Also being tested are the different bends and entry lengths leading up to the flow meter to find the more accurate piping geometry. The Reynolds number is a variable that is being used in the lab experiment. The scaling of the Reynolds number is important because the team wants to simulate SRP's fuel system. To do this the team has calculated the Reynolds number for SRP's system and compared it to air to solve for the velocity needed from the blower. Another variable is the pressure drop across the flow meters, this drop will help the team calculate the accuracy of the flowmeters. The team will be using the pressure taps and pressure sensor to get values for the pressure drop.

### **7.2.3 DATUM**

The team will use an ultrasonic flowmeter (Uniform 1010P universal portable flowmeter) as the DATUM for the whole experiment measurements. The team will refer to the Ultrasonic flowmeter measurements and will compare them to the measurements obtained from the Venturi flowmeter and the orifice plate flowmeter. The ultrasonic flowmeter will be fixed in



position throughout the multiple trials that the team will perform during the experiment, it will be positioned just before the bend. This is to guarantee a fully developed flow when measuring the flow. Based on the results that will be obtained from the ultrasonic flowmeter the team will perform a statistical and an analytical analysis that will determine the accuracy of both flowmeters that are being investigated, the orifice plate flowmeter and the Venturi flowmeter.

### 7.2.4 Impact of Flow Straightener

Flow straighteners have a strong impact on straightening up undeveloped flows that can happen after bends or change in the cross-sectional area of pipes. It can provide a fully developed flow after any bend angle that occurs during piping systems. This method can be done by placing small circular or quintuple paths inside the required pipe to make the flow forced to be uniform. The impact that this method can do is significant, especially for pipe systems that include many bends and cross-sectional area changes. The major benefit out of flow straighteners is saving space in systems, and making the ability of installing flow meter at any spot wanted. The reason beyond that is to have flow measurements with a uniform velocity profile, which will make meters calculate flows easier.




Figure 7.2.4a: Honeycomb flow straighteners




Figure 7.2.4: Honeycomb flow straightener. CAD design.



In the experiment, team 33 will install a flow straightener right after a bend to see how much it will affect the flow meter readings. The measuring process will be applied twice; the first one will be without the flow straighteners and the second one will be with them. The readings should differ, as it will be discussed in the expectations of the experiment, but the main idea here is to see where is the best length to put the flow meter after installing the flow straightener inside the pipe. The team will be using the honeycomb flow straighteners as the method of making flow as developed as possible.

### 7.2.5 Accuracy of orifice vs. Venturi

This section will include a thorough comparison between the orifice plate meter and the Venturi. The comparison will be based on the accuracy of both meters, with and without the flow straightener.

#### Orifice meter

The orifice meter is a sensitive meter that needs in most cases a long distance before installation. Due to impact of the diameter ratio on the reading measurement, a big consideration needed in the length of the straight pipe before the installation of the orifice meter as shown in the figure (7.2.5a). The length of the straight pipe can be estimated in some cases, but the main thing is considering the length of that straight pipe and knowing that it will affect the accuracy of the orifice readings.




Figure 7.2.5a: Orifice meter Diameter ratio.

### Venturi meter

On the other hand, venturi meter works mostly the same as orifice plate, except that it does not need that much of a space before installing it. The length of the upstream straight pipe will also depend on the diameter ratio as shown in the figure (7.2.5b).




Figure 7.2.5b: Venturi flowmeter diameter ratio.

For a regular application, the maximum downstream length should not exceed eight times of the diameter of the pipe. However, as long as venturi meter does not get affected by the downstream length it is reasonable to have more accurate readings on the venturi than the orifice with a serpentine piping systems.

Flow straighteners can have an impact on the measurement readings accuracy for different flow meter. However, in the experiment the team will be testing both orifice and venturi meter with different spots in the pipe system to see how much this effect will be on both the venturi and orifice meter. The flow straighteners will be added to the system after testing them without the flow straighteners. The datum will be the ultrasonic meter as the accuracy of our measurement from both the orifice and venturi meters. The certain spots that the orifice and venturi will be placed are discussed in the modeling section.

### 7.2.6 Impact of orifice diameter

One of the most important factors of an orifice plate’s accuracy and certainty is the ratio of the diameter of the orifice opening to the inner diameter of the pipe, denoted as  $\beta$ . Tables 7.2.6a and 7.2.6b shows the  $\beta$  values for the Agua Fria plant.

Table 7.2.6a: The ratios of the orifice plate diameter to the inner pipe diameter for each unit at Agua Fria Power Plant. Steam Units

Unit	$\beta$
1	0.634
2	0.634
3	0.639

Table 7.2.6b: The ratios of the orifice plate diameter to the inner pipe diameter for each unit at Agua Fria Power Plant. Steam Units. Gas Combustion Units

Unit	$\beta$
4	0.647
5	0.647
6	0.647

An article published by Emerson details some of the factors that contribute to a reduction in the reliability of an orifice plate. These factors include physical properties such as the construction tolerances of the meter, concentricity of the orifice hole, the smoothness of the meter tube surface, and the ratio of the orifice diameter to the inner pipe diameter [16]. This article provides Figure 7.2.6, pictured below. Based on this figure, the units are experiencing between 0.45% and 0.46%, which is substantial when looking at an overall error of 2%.




Figure 7.2.6: Percent uncertainty of an orifice plate with an infinite Reynold’s number

The team’s experiments will validate this in combination with the existing geometry at the

plant by testing orifice plates with different sized bore holes.

### 7.2.7 Impact of pipe geometry

Another important factor in orifice plate accuracy is the amount of straight diameter lengths upstream and downstream necessary for the flow to be fully-developed when it runs through the meter. The ISO installation requirement standards are listed in Table 7.2.6a below [17]. The units at Agua Fria Power Plant all have a single 90° bend with the exception of unit 3, which has a more complicated geometry that includes 3 90° bends in close succession. This pipe geometry is listed in Table 7.2.6b.

Table 7.2.7a: Upstream and downstream lengths required for 0% additional uncertainty (bracketed values signify +/- 0.5% accuracy) [17]

$\beta$	Upstream Straight Lengths				
	Single 90° Bend	Two 90° Bends in Perpendicular Planes	Reducer 2D to D Over 1.5D to 3D	Gate Valve Fully Open	Downstream
0.2	10(6)	34(17)	5	12(6)	4(2)
0.3	10(6)	34(17)	5	12(6)	5(2.5)
0.4	14(7)	36(18)	5	12(6)	6(3)
0.5	14(7)	40(20)	6(5)	12(6)	6(3)
0.6	18(9)	48(24)	9(5)	14(7)	7(3.5)
0.7	28(14)	62(31)	14(7)	20(10)	7(3.5)
0.75	36(18)	70(35)	22(11)	24(12)	8(4)

Table 7.2.6b: Number of straight diameter lengths upstream and downstream of the orifice plates.

Unit	1	2	3	4	5	6
Upstream Lengths	23.3	23.2	27.6	30	30	30
Downstream Lengths	6.36	6.50	5.4	12.5	12.5	12.5

Unit 3 clearly has a shorter upstream length than is necessary, but only to an additional 0.5% error. The other steam units are just on the verge of creating additional error. All 3 Gas Combustion Turbines have downstream lengths that are too short, but are under the 0.5% error. Therefore, there is good probability that these geometric problems are severely affecting the accuracy of the installed orifice meters. This will also be tested in the team’s experiment by adjusting the number of straight upstream and downstream lengths before both an orifice plate and a Venturi meter. This is because, as demonstrated in Table 7.2.6c below, a Venturi meter requires fewer straight diameter lengths.



Table 7.2.6c: Straight diameters required upstream for 0 error, with ISO recommendations

$\beta$	Single 90° Bend (R = 1.5D)		Two 90° Bends Same Plane		Two 90° Bends Perpendicular Planes		Reducer	
	Old	New	Old	New	Old <sup>a</sup>	New	3:1 Over	4:3 Over
							3.5D	2.3D
0.4	0.5	8	1.5	3	*	3	2.5	4
0.5	1.5	9	2.5	10	*	3	5.5	4
0.6	3.0	10	3.5	10	*	3	8.5	4
0.75	4.5	16	4.5	22	*	17	11.5	4

Note: At least four throat diameters should separate the throat tapping from downstream fittings.

<sup>a</sup> Indicates that no values are given without 0.5% additional uncertainty.

labeled Old and NEL propositions labeled New [17]

### 7.2.8 Expected Results

The team has some expected results for various parts for the experiment. These hypotheses include how the pipe geometry will affect the amount of necessary entrance length, how the flow straightener will also affect the entrance length, and the precision difference between the orifice plate and the Venturi tube.

#### Pipe Geometry

The team expects that the pipe geometry will play a significant role in the experiment. The experiment will try to replicate the pipe geometry discovered at SRP’s Agua Fria Generation plant. The expectation is that the more complex the geometry, meaning having more bends and diameter changes, the more undeveloped and turbulent the flow is going to be. Knowing this, the team can expect that with a more complex pipeline, more entrance length will be needed in order to develop the flow properly before the flowmeter.

#### Flow Straightener

The team will also be constructing and testing a flow straightener for this experiment. If the necessary entrance length for a flowmeter is longer than available, then the team expects that integrating a flow straightener will reduce the entrance length needed and will improve accuracy due to the flow being more developed than before.

#### Orifice vs. Venturi

In the experiment the team will test the accuracy of an orifice meter vs a venturi meter by taking flow measurements with the two meters at the same point along the pipe and then comparing the results with the DATUM calculated using the ultrasonic flow meter. The team expects that the venturi flow meter will have a higher degree of accuracy compared to the DATUM than the orifice meter will.

## 8 Testing

## 9 Conclusion

The mission for this project encompassed improving the fuel measurement accuracy of the flow meter system of the Aqua Fria SRP power plant. This was done by researching various types of flow meters and common sources of error to recommend options to our client. An experiment was conducted testing these parameters by simulating the SRP plant's fuel measurement system. Which consisted of testing the effect of different size orifice diameters, a flow straightener, upstream pipe length, and a Venturi tube vs. orifice plate. The team ran a precision analysis on the data taken to concur our hypothesis of these common errors. The team proposed to the client all the options that would reduce the error along with which option would be more cost efficient and decrease error. SRP liked the options that were presented and decided to look more into the Venturi tube option with the backup choice being installing a flow straightener.

The main ground rules were that our team would be professional and organized. The project success was due to the professional and adequate work put in by the whole team. All members were willing to put their best effort into the researching, designing, manufacturing and testing that went into the outcome of this project. All team members completed their work according to the deadlines that were set for each assignment. To stay organized everything was copied to google docs so all members could review all documents that have been completed throughout the two semesters. Since the ground rules were followed the outcome of the project was a success ending up with SRP liking the options proposed. The coping strategies involved solutions to conflicts that would arise throughout the project. There were no huge issues that arisen that needed coping, the team worked extremely well together which is portrayed by the outcome of the project.

**[Question 3]** The project had many positives to its completion when talking about the performance of the project itself. Communication between the team members was a crucial aspect to keep ahead of deadlines and the team did a great job of accomplishing a high level of communication. This allowed each team member to understand exactly where the other team members where they were within their parts of the project tasks and allowed questions and concerns to be answered quickly and accurately. Time management was another well done aspect from each of the team members as the team decided, most of the time, to make deadlines earlier than the university's deadlines. This allowed the team some recovery time in order to fix any issues with any deliverables as well as having some time to correctly format and proofread the deliverables as well. As for the experiment itself a major positive was that the expected results were the results that the team came up with at the end of the experiment. This was reassuring as the team did not run into any unexpected results and thus did not have to backtrack and reassess the experiment. As the team decided to scale down the experiment using PVC pipe the manufacturing costs of the project was very low as most of the material as most of the material was able to be purchased at local hardware stores. This low cost allowed the team to be able to purchase higher end sensors in order to get more precise readings which allowed for a more detailed precision analysis. The project did not go perfectly smooth as there was some issues that arose during the project's length.

**[Question 4]** Some negative aspects to the project arose during this year-long project. The first of these was the distance between the university and the power plant that was the team's project location. This led to only a few visits where the team needed to be efficient with their visits in order to get all the information to move forward. This also led to not as much communication between the team and power plant and its representatives as the team would have liked and some confusion because of this. In the beginning of the project the lack of communication to the client representative led to some confusion about what exactly the goal and the overall issue was with the power plant at first. Additionally with a project of this size is done the lack of an actual physical product can throw the team off, especially when other teams have a actual product and can see progress. This was, at first, a concern for the team as the team did not know where they stood on the progression of the project. Once the team came to terms that the deliverable was not an actual product but results of an experiment instead the team was able to shift their focus onto designing an experiment, performing an experiment, and finally analyzing the results in order to determine trends and relationships between various variables within the experiment. Many tools and methods allowed the team to accomplish the various tasks that the university and the clients gave the team.

**[Question 6]** The team has encountered many problems throughout the whole project. The first problems that the team faced were finding the reason behind the accuracy error, but this problem was solved by performing some intensive research on flow meters and power plants in general. The team has found many factors that can affect the measurement of the flow meter. Another problem the team faced was to replicate the piping system in Agua Fria power plant. With this being said, the team had to perform a non-dimensionalisation analysis to the parameters and factors that were collected during the experiment.

One problem that the team could not find a solution for was having a datum to compare the accuracy between the orifice plate and the venturi flow meters. The datum had to be either a very accurate meter (less than accuracy) or an ultrasonic meter. The ultrasonic was the meter used by the supplier. Having an accurate flow meter would make it easier to compare the measurement of both the flow meters. Unfortunately, the ultrasonic flow meter was expensive and exceeded our allocated budget. The team had to change the analysis from an accuracy analysis to a precision analysis, that can be related straight forward to the accuracy analysis. The team also encountered a problem in terms of having sufficient data to analyze from the company itself.

**[Question 7]** The team did a very good job of utilizing Google Drive services to keep all of our different documents separate and organized. Using this as an organizational tool helped to allow teammates to contribute to the completion of documents remotely when they were not able to be present at group meetings. Something that would have helped the group in terms of organization would have been to have some sort of schedule available online that detailed when the group was planning on meeting for the next few weeks. We used group text messages as well as word of mouth to determine when meetings would take place which sometimes led to group members being mistaken or unaware of meeting times.

**[Question 8]** Finally, the team learned how to effectively formulate an engineering problem and explore solutions from an engineering perspective. This awareness, both theoretically and practically, is crucial in the engineering profession because it defines what engineers are trained to do, which is solving problems using simple yet effective approaches. Currently, the team can identify an existing engineering concern and then compose equations and hypotheses that could solve the problem. With this being said, the team explored various flow meters and investigated the operating principles behind each flow meter. In addition, the team explored the operational system that controls power plants, and also how power plants actually operate. The technical communication skills that were developed as a result of communicating with professional engineers was very beneficial in terms of getting the team

ready for their professional careers.

## References

- [1] M. Duzen, "Turnkey natural gas measurement," in *flowcontrolnetwork.com*, Flow Control Network, 2014. [Online]. Available: <http://www.flowcontrolnetwork.com/turnkey-natural-gas-measurement/>. Accessed: Sep. 20, 2016.
- [2] "How gas turbine power plants work,". [Online]. Available: <http://energy.gov/fe/how-gas-turbine-power-plants-work>. Accessed: Sep. 25, 2016.
- [3] G. Electric, "Combined-cycle power plant – how it works | GE power generation," in Power Generation, 2016. [Online]. Available: <https://powergen.gepower.com/resources/knowledge-base/combined-cycle-power-plant-how-it-works.html>. Accessed: Sep. 25, 2016.
- [4] J. Mollerup and P. Angelo, "Measurement and correlation of the volumetric properties of a synthetic natural gas mixture", *Fluid Phase Equilibria*, vol. 19, no. 3, pp. 259-271, 1985
- [5]"» The Transportation of Natural Gas NaturalGas.org", *Naturalgas.org*, 2016. [Online]. Available: <http://naturalgas.org/naturalgas/transport/>. [Accessed: 28- Sep- 2016].
- [6]"Combustion Engine for Power Generation- Introduction", *Wartsila.com*, 2016. [Online]. Available: <http://www.wartsila.com/energy/learning-center/technical-comparisons/combustion-engine-for-power-generation-introduction>. [Accessed: 30- Sep- 2016].
- [7]"EIA - Natural Gas Pipeline Network - Transportation Process & Flow", *Eia.gov*, 2016. [Online]. Available: [https://www.eia.gov/pub/oil\\_gas/natural\\_gas/analysis\\_publications/ngpipeline/process.html](https://www.eia.gov/pub/oil_gas/natural_gas/analysis_publications/ngpipeline/process.html). [Accessed: 30- Sep- 2016].
- [8] "Coriolis mass flow measuring principle Archives - Instrumentation Tools", *Instrumentation Tools*, 2016. [Online]. Available: <http://instrumentationtools.com/tag/coriolis-mass-flow-measuring-principle/>. [Accessed: 27-Oct- 2016].
- [9] "Types of Fluid Flow Meters", *Engineeringtoolbox.com*, 2016. [Online]. Available: [http://www.engineeringtoolbox.com/flow-meters-d\\_493.html](http://www.engineeringtoolbox.com/flow-meters-d_493.html). [Accessed: 27-Oct- 2016].
- [10] "Webtec – Hydraulics," Webtec.com, 2016. [Online]. Available: <http://www.webtec.com/en/tech/reports/turbine>. [Accessed: 29- Oct- 2016].
- [11] Emerson, "FloBoss 107E Flow Manager" [Online} Available: <http://www2.emersonprocess.com/en-US/brands/FloBoss/gasflowcomputers/107E/Pages/107E.aspx>. [Accessed 25-Oct-2016]

[12]"Gas turbine engines -", *Petrowiki.org*, 2016. [Online]. Available:  
[http://petrowiki.org/Gas\\_turbine\\_engines](http://petrowiki.org/Gas_turbine_engines). [Accessed: 29- Sep- 2016].

[13]"Venturi tube Flowmeter to measure gas," [www.alibaba.com](http://www.alibaba.com), 1999. [Online]. Available:  
[https://www.alibaba.com/product-detail/venturi-tube-flowmeter-to-measure-gas\\_1233261483.html](https://www.alibaba.com/product-detail/venturi-tube-flowmeter-to-measure-gas_1233261483.html). Accessed: Nov. 22, 2016.

- [14] R. S. Figliola and D. E. Beasley, *Theory and design for mechanical measurements*, 3rd ed. New York, NY: John Wiley and Sons (WIE), 2000.
- [15] T. G. Beckwith, Roy D., and John H., *Mechanical Measurements*, fifth edition ed. United States: Addison Wesley, 1995
- [16] J. P. Holman, Holman, and Search our Used & Out of... Holman, *Solutions manual to accompany experimental methods for engineers, sixth edition*, 6th ed. New York: McGraw Hill Higher Education, 1993
- [17] Emerson (2010). *Theoretical Uncertainty of Orifice Flow Measurement* [Online]. ETA Process Instrumentation.
- [18] R. C. Baker, "Orifice Plate Meters" & "Venturi Meter and Standard Nozzles," in *Flow Measurement Handbook: Industrial Designs, Operating Principles, Performance, and Applications*, Cambridge, UK: Cambridge, 2000, ch. 5 & 6, pp. 95-139.

## Appendix A

*Matlab codes for flow rate calculations in orifice plate and Venturi.*

```

clc
clear

%These equations can be applied on obstruction meters (orifice &
venturi)%

%fluid's composition%
Nitrogen=[0.31 0.31 0.31 0.32 0.32 0.31 0.31 0.31 0.31 0.31] %changes
at unit#4&5%
CO2=[1.28 1.28 1.28 1.28 1.28 1.28 1.28 1.28 1.28 1.28] %constant%
Methane=[97.23 97.23 97.23 97.22 97.22 97.23 97.23 97.23 97.23 97.23]
%changes at unit#4&5%
Ethane=[0.93 0.93 0.93 0.93 0.93 0.93 0.93 0.93 0.93 0.93] %constant%
Propane=[0.19 0.19 0.19 0.19 0.19 0.19 0.19 0.19 0.19 0.19]
%constant%
nButane=[0.02 0.02 0.02 0.02 0.02 0.02 0.02 0.02 0.02 0.02]
%constant%
iButane=[0.03 0.03 0.03 0.03 0.03 0.03 0.03 0.03 0.03 0.03]
%constant%
nPentane=[0 0 0 0 0 0 0 0 0 0] %constant%
iPentane=[0 0 0 0 0 0 0 0 0 0] %constant%
Hexane=[0.01 0.01 0.01 0.01 0.01 0.01 0.01 0.01 0.01 0.01] %constant%
Heptane=[0 0 0 0 0 0 0 0 0 0] %constant%
Octane=[0 0 0 0 0 0 0 0 0 0] %constant%
Nonane=[0 0 0 0 0 0 0 0 0 0] %constant%
Decane=[0 0 0 0 0 0 0 0 0 0] %constant%
H2S=[0 0 0 0 0 0 0 0 0 0] %constant%
Water=[0 0 0 0 0 0 0 0 0 0] %constant%
Helium=[0 0 0 0 0 0 0 0 0 0] %constant%
Oxygen=[0 0 0 0 0 0 0 0 0 0] %constant%
CO=[0 0 0 0 0 0 0 0 0 0] %constant%
Hydrogen=[0 0 0 0 0 0 0 0 0 0] %constant%

%meters setup%

n=[1 2 3 4 5 6 7 8 9 10] %unit#1-#10%
density_air=1.23 %density of air at T=15 celsius in kg/m^3%
patm=14.12841 %atmospheric pressure in psi%
g=32.11277 %gravitational accelaration ft/s^2%
Mu=0.6 %viscosity in cp%
density=[1.588 2.083 0.001 11.895 11.906 11.935 5.734 5.753 5.757
5.778] %denstiy at each orifice plate in kg/m^3%
%http://unitrove.com/engineering/tools/gas/natural-gas-density%

%changing the givens to SI units%

```

```

SG=0.5758 %specific gravity for all units%
k=1.3 %specific heat ratio for all units%
Patm=97411.957886 %atmospheric pressure in pa for all units%
G=9.787972296 %gravitational accelaration in m/s^2 for all the units%
MU=0.0006 %viscosity in N.s/m^2%
Density=SG*density_air %density of natural gas from specific of
gravity in kg/m^3%
R=0.287058 %gas constant of natural gas in KJ/Kg*k%

d0=[8.8712 8.8759 10.2199 3.883 3.883 3.883 2.3748 4.9988 6.0003
7.0009] %orifice diameter in inches for all units (flow meters)%
d1=[14 14 16 6 6 6 4.023 11.937 11.941 11.937] %pipe diameter in
inches for all units (flow meters)%

D0=d0.*0.0254 %diameter in m%
D1=d1.*0.0254 %diameter in m%

B=D0./D1 %diameters coefficient%

A0=(pi./4).*D0.^2 %orifice plate cross-section area in m^2 for all
units (flow meters)%
A1=(pi./4).*D1.^2 %pipe cross-section area in m^2 for all units (flow
meters)%

E=1./sqrt(1-B.^4) %coefficient%

Delta_p=[0.0671479 -0.0842513 0.0420168 0.0167982 -0.0336361 -
0.0757066 0.0587801 0.0503626 -0.0168554 -0.0084084] %change in
pressure in inH2O for all units (flow meters)%
p1=[32.89332 43.31176 0.0269687 246.2265 246.1623 246.1391 125.3776
125.5657 125.6203 125.6866] %static pressure in psi for all units
(flow meters)%

Delta_P=Delta_p.*249.088875 %change in pressure in pa%
P1=p1.*6894.75729 %static pressure in pa%
P2=P1-abs(Delta_P) %pressure after orifice plate in pa%

Tf=[58.48682 60.05267 65.5163 71.51623 70.9614 69.74372 91.4132
90.4752 90.43119 88.81457] %flow tempreture in Fehrenheit for all
units (flow meters)%
Tc=(Tf-32)*(5/9) %flow tempreture in celsius for all units (flow
meters)%
Tk=Tc+273.15 %flow tempreture in kelvin for all units (flow meters)%

%flow rate for incompressible flow%
C=0.965 %discharge coefficient% %0.95<C<0.98 for venturi%
%C=Q_actual/Q_ideal%
K=C*E %coefficient%

```



```

Q_ideal=(A0./sqrt((1-
(A0./A1).^2))).*sqrt((2.*G.*abs(Delta_P))./Density) %Ideal flow rate
at each orifice plate in m^3/s 'incompressible flow assumption'%
Q_actual=(K.*A0).*sqrt(2.*G./Density).*sqrt(abs(Delta_P)) %actual
flow rate at each orifice plate in m^3/s 'incompressible flow
assumption'%
M=Q_actual.*Density %mass flow rate in kg/s%
v1=Q_actual./A1 %velocity of natural gas before entering the orifice
plate in m/s%
v2=Q_actual./A0 %velocity of natural gas after entering the orifice
plate in m/s%

Q_ft=Q_actual.*35.3146667 %flow rate in each orifice plate in ft^3/s%
Q1_ft=Q_ideal.*35.3146667

TD=max(Q_actual)./min(Q_actual) %the turndown of orifice plate%

c=sqrt(k.*R.*Tk) %speed of sound in m/s at each unit%
Ma=v1./c %Mach number for all units (flow meters)%
Re_d1=(Density.*v1.*D1)./MU %Reynold's number of pipes for all units
(flow meters)%
hL=(abs(Delta_P)./Density) %head losses of orifice plate in KJ/KG for
all units (flow meters)%

%flow rate for compressible flow in orifice plate%
Y=1-(0.41+0.35.*B.^4).* (abs(Delta_P)./(k.*P1)) %Expansion factor for
orifice plates%
Q_c_actual=((Y.*K.*A0)./Density).*sqrt(2.*G.*Density.*abs(Delta_P))
%Actual flow rate for the compressible flow in m^3/s%

Q_c_ft=Q_c_actual.*35.3146667 %flow rate in each orifice plate in
ft^3/s%

%flow rate for compressible flow in venturi%
Y1=((P2./P1).^ (2./k) .* (k./ (k-1)) .* ((1-(P2./P1) .^ ((k-1) ./k)) ./ (1-
(P2./P1))) .* ((1-B.^4) ./ (1-B.^4 .* (P2./P1) .^ (2./k)))) .^0.5 %Expansion
factor for venturi%
Q_c1_actual=((Y1.*K.*A0)./Density).*sqrt(2.*G.*Density.*abs(Delta_P))
%Actual flow rate for the compressible flow in m^3/s%

Q_c1_ft=Q_c1_actual.*35.3146667 %flow rate in each orifice plate in
ft^3/s%

difference_between_orifice_and_venturi_pecentage=((Q_c_ft-
Q_c1_ft)./Q_c_ft).*100

```

%Assumptions made%

%B for venturi is the same as Orifice plate%

%Density of natural gas%

%Gas constant of natural gas 'R'%

%dischage coefficient 'C'%

%venturi pressure readings are the same as orifice pressure readings%